

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs)

Name and address of the applicant

HIMEL HONG KONG LIMITED  
11/F Kerry Ctr 683 King's Rd Quarry Bay  
Hong Kong

Name and address of the manufacturer

DELIXI ELECTRIC LTD  
Delixi High Tech Industrial Park, Liushi Town, Yueqing City  
Zhejiang Province, China 325604

Name and address of the factory

Note: When more than one factory, please report on page 2

See page 2

Ratings and principal characteristics

See page 2

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

HDB3LE, HDB3LEG

Additional information (if necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 61009-1:2010+A1+A2  
IEC 61009-2-2:1991

As shown in the Test Report Ref. No. which forms part of this Certificate

211201643SHA-001, 211201643SHA-002

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB  
Torshamnsgatan 43  
Box 1103  
SE-164 22 Kista, Sweden

intertek

Signature:

Henrik Wikström

Date: 11 January, 2022

### Factories

DELIXI ELECTRIC LTD  
Delixi High Tech Industrial Park  
Liushi Town, Yueqing City,  
Zhejiang Province, China 325604

DELIXI ELECTRIC (WUHU) LTD.  
Wuhu Machinery Industrial Park  
Wuhu City, Anhui Province, China 241100

### Ratings and principal characteristics

$U_n = 230V\sim$  or  $240V\sim$  for 2P(1P+N),  $400V\sim$  or  $415V\sim$  for 3P, 4P(3P+N)  
 $I_n = 6, 10, 16, 20, 25, 32, 40, 50, 63A$ , B- & C- & D- type; 50/60Hz;  
 $I_{\Delta n} = 10mA$ (only for 2P), 30mA, 50mA, 75mA, 100mA, 300mA; Type-A & -AC  
 $I_{cs} = I_{cn} = 6000A$ ,  $I_{\Delta m} = 2000A$

Date: 11 January, 2022

Signature:

