


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Surge Protective Devices
Name and address of the applicant	Himel Hong Kong Limited 11/F Kerry Ctr 683 King's Rd, 999077 Quarry Bay, Hong Kong
Name and address of the manufacturer	Delixi Electric Ltd. Delixi High Tech Industrial Park, Liushi Town, 325604 Yueqing Zhejiang, China
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 Delixi Electric Ltd. Delixi High Tech Industrial Park, Liushi Town, 325604 Yueqing Zhejiang, China
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	Test class II / Type 2; Iscrr: 500 A; IP20; Uc: 275 V~ / 385 V~ / 440V~ (L-N), 255 V~ (N-PE); In: 10 kA / 20 kA / 30 kA (L-N), 30 kA (N-PE); Imax: 20 kA / 40 kA / 65 kA (L-N), 65 kA (N-PE); Up: 1,3 kV / 1,5 kV / 1,6 kV / 1,8 kV / 2,0 kV / 2,2 kV (L-N), 1,5 kV (N-PE)
Trademark (if any)	 HIMEL
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	HDY3N/XX/YYYY-ZZZ, see pages 6 to 7 of test report 6114693.50 to 6114693.52 in detail
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61643-11:2011 National differences: EU Group Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	6114693.50 to 6114693.52

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands