




# ATTESTATION of conformity with European Directives



*Product:* **Switch-disconnector**  
*Reference* **HDG3**  
*Issued to* **HIMEL HONG KONG LIMITED**  
*Address* **11/F KERRY CTR 683 KING'S RD QUARRY BAY HONG KONG**  
*Manufacturer* **DELIXI ELECTRIC LTD**  
**Utilization category: AC-22A**  
**Ue:230V for 1P; 400V for 2P/3P/4P**  
**Ie: 20A, 25A, 32A, 40A, 63A, 80A,100A, 125A**  
**Ui: 500V**  
**Uimp: 6kV**  
**Icw: 15Ie/1s**  
*Technical characteristics* **Icm:**  
**21,15Ie for 20A, 25A, 32A, 40A, 63A**  
**21,3Ie for 80A,100A, 125A**  
**Rated frequency: 50/60Hz**  
**Distance for metal screen: Back:0mm Front:0mm; Top:45mm**  
**Botton:45mm; Left:0mm Right:0mm(values declared by client)**

The submitted sample of the above equipment has been tested for  marking according to following European Directive and following standards:

**Low Voltage Directive 2014/35/EU**

<i>Standards</i>	<i>Report number</i>	<i>Report date</i>
<b>EN 60947-1:2007+A1:2011+A2:2014; EN 60947-3:2009+A1:2012+A2:2015;</b>	<b>B200068</b>	<b>2021-01-08</b>

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product  
The  marking may be affixed if all relevant and effective European Directives with  are applicable

Shanghai (P.R. China), February 4th, 2021.

**Charlie CHEN**  
**Product Line Manager**



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.  
Information given in this document, are related to the tested specimen of the described electrical sample.