

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50496460

Blatt *Sheet*
0003

Ihr Zeichen *Client Reference*
G.J.Q.

Unser Zeichen *Our Reference*
01-DJL-CN21CUQM 004

Ausstellungsdatum *Date of Issue*
16.07.2021
(day/mo/yr)

Genehmigungsinhaber *License Holder*
HIMEL HONG KONG LIMITED
11/F KERRY CTR
683 KING'S RD QUARRY BAY
Hong Kong

Fertigungsstätte *Manufacturing Plant*
040-0002049604

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
EN 60947-2:2017+A1

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Moulded case circuit breaker (MCCB)

as page 0001

Addition Type Designation : HDM3S-400M 8
Selectivity Category : A
Type of Release : Thermo-magnetic; Magnetic
Reference Temperature : +40°C or +50°C
Number of Poles : 3P, 4P(with switched N pole)
Rated Operational Voltage(Ue) : AC400/415V
Rated Current(In) : 250/320/350/400A
Rated Ultimate Short-circuit Breaking Capacity(Icu) : 50kA
Rated Service Short-circuit Breaking Capacity(Ics) : 50kA
Rated Impulse Withstand Voltage(Uimp) : 8,0kV
Rated Insulation Voltage(Ui) : 1000V
Suitability for Isolation : Yes
Pollution Degree : 3
IP Code : IP20

8

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle



Wencai Zhang

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50496460

Blatt *Sheet*
0004

Ihr Zeichen *Client Reference*
G.J.Q.

Unser Zeichen *Our Reference*
01-DJL-CN21CUQM 004

Ausstellungsdatum *Date of Issue*
16.07.2021
(day/mo/yr)

Genehmigungsinhaber *License Holder*
HIMEL HONG KONG LIMITED
11/F KERRY CTR
683 KING'S RD QUARRY BAY
Hong Kong

Fertigungsstätte *Manufacturing Plant*
040-0002049604

Prüfzeichen *Test Mark*



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 1111236893

Geprüft nach *Tested acc. to*
EN 60947-2:2017+A1

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Moulded case circuit breaker (MCCB)

as page 0001

Addition Type Designation	: HDM3S-630M	8
Selectivity Category	: A	
Type of Release	: Thermo-magnetic; Magnetic	
Reference Temperature	: +40°C or +50°C	
Number of Poles	: 3P, 4P(with switched N pole)	
Rated Operational Voltage(Ue)	: AC400/415V	
Rated Current(In)	: 400/500/630A	
Rated Ultimate Short-circuit Breaking Capacity(Icu)	: 50kA	
Rated Service Short-circuit Breaking Capacity(Ics)	: 50kA	
Rated Impulse Withstand Voltage(Uimp)	: 8,0kV	
Rated Insulation Voltage(Ui)	: 1000V	
Suitability for Isolation	: Yes	
Pollution Degree	: 3	
IP Code	: IP20	

8

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety



Wencai Zhang

HIMEL HONG KONG LIMITED
Jianquan Guo

11/F KERRY CTR
683 KING'S RD QUARRY BAY
Hong Kong

Date : 16.07.2021
Our ref. : DJL 01
Your ref.: G.J.Q.

Ref : R TÜV-Mark Approval

Type of Equipment : MCCB
Model Designation : See Certificate
Certificate No. : R 50496460 0003
Report No. : CN21CUQM 004

Dear Jianquan Guo,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.

Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProDSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area.

With kind regards,

Certification Body



Wencai Zhang

cc: DELIXI ELECTRIC LTD

Enclosure

证书的详细资料请登陆www.tuvdotcom.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

C E R T I F I C A T E



of Conformity
Low Voltage Directive 2014/35/EU

Registration No.: AN 50511967 0001

Report No.: CN21CUQM 004

Holder: HIMEL HONG KONG LIMITED
11/F KERRY CTR
683 KING#S RD QUARRY BAY
Hong Kong

Product: Moulded case circuit breaker
(MCCB)

Identification: Type Designation: HDM3S-160M , HDM3S-250M ,
HDM3S-400M , HDM3S-630M

Serial No. : Engineering sample

Remark: Issued in conjunction with TÜV Rheinland license
R 50496460 0001-0004.

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

Certification Body

Date 16.07.2021



TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

CE The CE marking may be used if all relevant and effective EC Directives are complied with. CE

HIMEL HONG KONG LIMITED
Jianquan Guo

Date : 16.07.2021
Our ref. : DJL 01
Your ref.: G.J.Q.

11/F KERRY CTR
683 KING#S RD QUARRY BAY
Hong Kong

Ref : AN Certificate of Conf. Low Voltage D.

Type of Equipment : MCCB
Model Designation : See Certificate
Certificate No. : AN 50511967 0001
Report No. : CN21CUQM 004

Dear Jianquan Guo,


We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body



Wencai Zhang

CC: DELIXI ELECTRIC LTD

Enclosure

证书的详细资料请登陆www.tuvdotcom.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询