



Ref. Certif. No.

HU-003385

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product	RCCB
Name and address of the applicant	HIMEL HONG KONG LIMITED 11/F KERRY CTR 683 KING'S RD QUARRY BAY, Hong Kong
Name and address of the manufacturer	DELIXI ELECTRIC LTD Delixi High Tech Industrial Park, Liushi Town, Yueqing City, 325604 Zhejiang, P.R. China
Name and address of the factory	DELIXI ELECTRIC LTD Delixi High Tech Industrial Park, Liushi Town, Yueqing City, 325604 Zhejiang, P.R. China
Ratings and principal characteristics	Un=230-240V ~ (2P); 400-415V ~ (4P); 50/60Hz; In=10/16/20/25/32/40/63A; IΔn=10mA (only for 2P, In=10/16/20/25A); 30/100/300/500mA; type A or type AC; IΔm=500A or 10In; IΔc=Inc=6kA
Trademark (if any)	Himel
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	HDB3VR
Additional information (if necessary may also be reported on page 2)	Detailed information refer to test report CN2109XD 001.
A sample of the product was tested and found to be in conformity with	IEC 61008-1:2010+A1+A2 IEC 61008-2-1:1990 See Test Report for National Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	CN2109XD 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division  
H-1143 Budapest, Gizella út 51-57., Hungary  
Web: www.tuv.com

Date: 2021-04-06

Signature: Wencai Zhang