

# ATTESTATION OF CONFORMITY

Issued to: HIMEL HONG KONG LIMITED  
11/F KERRY CTR 683 KING'S RD  
999077 Quarry Bay, Hong Kong, China

For the product: Circuit-breakers for overcurrent protection

Trade name: HIMEL

Type/Model: HDB9H

Ratings: 1P, 1P+N, 2P, 3P, 3P+N, 4P (N pole without overcurrent protection)  
Ue: 230 / 400 Vac for 1P, 230 Vac for 1P+N, 400 Vac for 2P, 3P, 3P+N, 4P  
50 / 60 Hz, In: 1, 2, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63 A, B, C and D type  
Ics = 7,5 kA, Icn = Icn1 = 10 kA, the grid distance "a" = 35 mm, energy limiting class  
3 for 1P, 2P, 3P, 4P and class 1 for 1P+N, 3P+N with type B and C

Manufactured by: DELIXI ELECTRIC LTD  
Delixi High-Tech Industrial Park Liushi Town, Yueqing City  
325604 Zhejiang Province, China

Subject: Type Test

Requirements: EN 60898-1:2019, IEC 60898-1:2015

Remark: This Attestation is based on AoC no. 3317630.01A issued on 2020-09-23.

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in reports no. 3317634.50 issued on 2020-11-12, 3317630.50 issued on 2020-09-14, 3315402.50 issued on 2019-04-23, 3310158.50 issued on 2016-06-27, 3307909.50 issued on 2015-06-29, 3304921.50 issued on 2013-04-18 and 3303848.50 issued on 2012-10-10.

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Wenzhou, Zhejiang, 20 November 2020      Number: 3317634.01A

DEKRA Testing Services (Zhejiang) Co., Ltd

Ms J Guo  
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

