

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Residual current operated circuit-breakers with
integral overcurrent protection (RCBOs)

Name and address of the applicant

HIMEL TECHNOLOGY, S.L.
calle Bac de Roda, No.52, edificio A,
08019 Barcelona, Spain

Name and address of the manufacturer

HIMEL TECHNOLOGY, S.L.
calle Bac de Roda, No.52, edificio A,
08019 Barcelona, Spain

Name and address of the factory

See on page 2

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Ue = 240V~ (1P+N); 415V~ (3P+N); 50/60Hz;
(RCBO with interrupted neutral)
In = 6A, 10A, 16A, 20A, 25A, 32A, 40A, 45A, 50A, 63A;
C-type; IΔn: 30mA, 300mA; Type AC;
IΔm: 3000A; Ics=Icn=6kA

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

HDB9LM

Additional information (if necessary may also be
reported on page 2)

A sample of the product was tested and found
to be in conformity withIEC 61009-1:2010 + AMD1:2012 + AMD2:2013
IEC 61009-2-1:1991
EU Group DifferencesAs shown in the Test Report Ref. No. which forms part
of this Certificate

1W170079-A1

This CB Test Certificate is issued by the National Certification Body



Date: 2017-04-06

TÜV Rheinland InterCert Kft., Division MPEI
H-1132 Budapest, Váci út 48/A-B
www.tuv.hu

Signature:

Gabor Kassai



IEC

IECEE
CB
SCHEME

Ref. Certif. No.

HU-001973

Factories:

- 1) DELIXI ELECTRIC LTD
Delixi High Tech Industrial Park, Liushi Town,
Yueqing City, Zhejiang Province,
China 325604
- 2) DELIXI ELECTRIC (WUHU) LTD
Wuhu Machinery Industrial Park, Wuhu city,
Anhui Province, China 241100

Additional information (if necessary)



TÜVRheinland®

Date: 2017-04-06

TÜV Rheinland InterCert Kft., Division MEEI
H-1132 Budapest, Váci út 48/A-B
www.tuv.hu

Signature:



Gabor Kassai