

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50391661

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*
G.J.Q.

Unser Zeichen *Our Reference*
01-DY-50105814 002

Ausstellungsdatum *Date of Issue*
26.10.2017
(day/mo/yr)

Genehmigungsinhaber *License Holder*
HIMEL TECHNOLOGY, S.L.
calle Bac de Roda,
No. 52, edificio A
08019 BARCELONA
Spain

Fertigungsstätte *Manufacturing Plant*
030-0000486222

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
EN 61009-1:2012+A1+A2+A11+A12

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Earth Leakage Circuit Breaker (RCBO)

Type Designation	: 1) HDB9PLEN (Himel) 2) HDB9PLEa	9 1
Number of Poles	: 1P+N	
Rated Voltage (Ue)	: AC 240V; 50/60Hz	
Rated Current (In)	: 6/10/16/20/25/32/40A	
Instantaneous Tripping Current	: C-type	
Behaviour in Presence of d.c.		
Components	: Type AC	
Rated Residual Operating Current	: 10mA; 30mA; 100mA	
Rated Short-circuit Capacity (Icn)	: 1) 6,0kA 2) 4,5kA	
Rated Service Short-circuit Capacity (Ics)	: Same as Icn	
Breaking Capacity	: 500A	
Rated Residual Making and		
Rated Insulation Voltage (Ui)	: 500V	

9

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety



Jie Zhang

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50391661

Blatt *Sheet*
0002

Ihr Zeichen *Client Reference*
G.J.Q.

Unser Zeichen *Our Reference*
01-DY-50105814 002

Ausstellungsdatum *Date of Issue*
26.10.2017 (day/mo/yr)

Genehmigungsinhaber *License Holder*
HIMEL TECHNOLOGY, S.L.
calle Bac de Roda,
No. 52, edificio A
08019 BARCELONA
Spain

Fertigungsstätte *Manufacturing Plant*
030-0000486222

Prüfzeichen *Test Mark*



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 1419052189

Geprüft nach *Tested acc. to*
EN 61009-1:2012+A1+A2+A11+A12

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Earth Leakage Circuit Breaker (RCBO)

Continuation from page 0001


Rated Impulse Withstand Voltage (U_{imp}) : 4,0kA
Method of Operation : Functionally Independent of Line Voltage
Time-delay : General type
Ambient Temperature Limits : -25°C to +40°C
Suitability of Isolation : Yes
Pollution Degree : 2

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle



Jie Zhang

HIMEL TECHNOLOGY, S.L.
Guo Jianquan

-
calle Bac de Roda,
No. 52, edificio A
08019 BARCELONA
Spain

Date : 26.10.2017
Our ref. : DY 01
Your ref.: G.J.Q.

Ref : R TÜV-Mark Approval

Type of Equipment : RCBO
Model Designation : See Certificate
Certificate No. : R 50391661 0001
Report No. : 50105814 002

Dear Guo Jianquan,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.

Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area.

With kind regards,

Certification Body


Jie Zhang

cc: DELIXI ELECTRIC LTD

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

DELIXI ELECTRIC LTD
Mr. Guo Jianquan
-
Delixi High Tech Industrial Park,
Liushi Town, Yueqing City,
Zhejiang Province 325604
P. R. China

Date : 26.10.2017
Our ref. : DY 01
Your ref.: G.J.Q.

Ref : R TÜV-Mark Approval

Type of Equipment : RCBO
Model Designation : See Certificate
Certificate No. : R 50391661 0001
Report No. : 50105814 002

Dear Mr. Guo Jianquan,

Enclosed please find above certification documents.
Please forward these originals to the certificate holder.

If you contact our office, please quote our reference above.

We thank you for your cooperation.

the certificate holder is: HIMEL TECHNOLOGY, S.L.

With kind regards,

Certification Body


Jie Zhang

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询