

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50350718

Blatt *Page*
0001

Ihr Zeichen *Client Reference*
G.J.Q.

Unser Zeichen *Our Reference*
01-DY-50048297 002

Ausstellungsdatum *Date of Issue*
05.07.2016
(day/mo/yr)

Genehmigungsinhaber *License Holder*

HIMEL TECHNOLOGY, S.L.
calle Bac de Roda,
No. 52, edificio A
08019 BARCELONA
Spain

Fertigungsstätte *Manufacturing Plant*

01-DY-50048297 001

Prüfzeichen *Test Mark*



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 1419037169

Geprüft nach *Tested acc. to*
EN 60947-3:2009+A1+A2

**Zertifiziertes Produkt (Geräteidentifikation)
*Certified Product (Product Identification)***

**Lizenzentgelte - Einheit
*License Fee - Unit***

Switch (Switch-disconnector)

Type Designation : HDG9 8

Number of Poles : 1P, 2P, 3P, 4P

Utilization Category : AC-22A

Rated Operational Voltage(Ue) : AC230V(1P); AC400V(2P, 3P, 4P)

Rated Frequency : 50/60Hz

Rated Operational Current(Ie) : 32A, 63A, 100A, 125A

Rated Insulation Voltage(Ui) : 500V

Conventional Free Air Thermal Current(Ith) : Same as Ie

Rated Short-time Withstand Current(Icw) : 20Ie, 1s

Rated Short-circuit Making Current(Icm) : 28Ie

Rated Impulse Withstand Voltage(Uimp) : 6,0kV

Continued on page 0002

8

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle



Jie Zhang

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50350718

Blatt *Page*
0002

Ihr Zeichen *Client Reference*
G.J.Q.

Unser Zeichen *Our Reference*
01-DY-50048297 002

Ausstellungsdatum *Date of Issue*
05.07.2016
(day/mo/yr)

Genehmigungsinhaber *License Holder*
HIMEL TECHNOLOGY, S.L.
calle Bac de Roda,
No. 52, edificio A
08019 BARCELONA
Spain

Fertigungsstätte *Manufacturing Plant*
01-DY-50048297 001

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
EN 60947-3:2009+A1+A2

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Switch (Switch-disconnector)

Continuation from page 0001

Degree of Protection : IP20
Pollution Degree : 3
Suitability for Isolation : Yes

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety



Jie Zhang

HIMEL TECHNOLOGY, S.L.
Guo Jianquan
-
calle Bac de Roda,
No. 52, edificio A
08019 BARCELONA
Spain

Date : 05.07.2016
Our ref. : DY 01
Your ref.: G.J.Q.

Ref : R TÜV-Mark Approval

Type of Equipment : Switch-disconnector
Model Designation : See Certificate
Certificate No. : R 50350718 0001
Report No. : 50048297 002

Dear Guo Jianquan,

The above specified technical equipment has been tested and found to be in accordance with the relevant requirements.

Enclosed you will find the certificate of approval.

If cancellation of the certificate is submitted by November 15 in a given year, no fee will be charged for the following year.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

Please contact our office for approval of your new products.

With kind regards,

Certification Body


Jie Zhang

cc: DELIXI ELECTRIC LTD

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

DELIXI ELECTRIC LTD
Mr. Guo Jianquan
-
Delixi High Tech Industrial Park,
Liushi Town, Yueqing City,
Zhejiang Province 325604
P.R. China

Date : 05.07.2016
Our ref. : DY 01
Your ref.: G.J.Q.

Ref : R TÜV-Mark Approval

Type of Equipment : Switch-disconnector
Model Designation : See Certificate
Certificate No. : R 50350718 0001
Report No. : 50048297 002

Dear Mr. Guo Jianquan,

Enclosed please find above certification documents.
Please forward these originals to the certificate holder.


If you contact our office, please quote our reference above.

We thank you for your cooperation.

the certificate holder is: HIMEL TECHNOLOGY, S.L.

With kind regards,

Certification Body


Jie Zhang

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询