

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Thermal overload relay

Name and address of the applicant

HIMEL HONG KONG LIMITED
11/F KERRY CTR 683 KING'S RD QUARRY BAY
HONG KONG

Name and address of the manufacturer

DELIXI ELECTRIC LTD
Delixi High Tech Industrial Park, Liushi Town, Yueqing City,
325604 Zhejiang Province, China

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as manufacturer

Ratings and principal characteristics

See page 2

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

HDR3s-630/F

Additional information (if necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 60947-4-1:2018,
IEC 60947-5-1:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

201200603SHA-001, -002

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

intertek

Signature:

Henrik Wikström

Date: 13 January, 2021

Rating and principal characteristics:

Type:	HDR3s-630/F		
Rating:	U _i = 690V, 3 poles, U _{imp} = 6kV, IP20, 50/60Hz		
Main circuit:			
U _e (V):	690		
I _e , AC-3 (A):	145-160-180-200	180-200-225-250	230-260-280-320
	290-325-360-400	350-395-440-480	460-520-570-630
Trip class:	10		
I _r (A):	18000		
I _q (A):	50000		
Auxiliary circuit:			
U _e (V):	AC 240	AC 415	DC 240
I _e , (A):	AC-15: 1,64	AC-15: 0,95	DC-13: 0,23
I _{th} (A):	6		

Date: 13 January, 2021

Signature:

