

# ATTESTATION OF CONFORMITY

Issued to: DELIXI ELECTRIC LTD  
Delixi High-Tech Industrial Park  
Liushi Town, Yueqing City  
325604 Zhejiang Province, China

For the product: Air Circuit-Breaker

Trade name: HIMEL

Type/Model: HDW3-2000M and HDW3-2000S

Ratings: Ue: 400 / 415 Vac, 660 / 690 Vac, 50 / 60 Hz,  
Ui: 1000 V, Uimp: 12 kV  
In: 630 A, 800 A, 1000 A, 1250 A, 1600 A, 2000 A  
See annex for further ratings

Manufactured by: DELIXI ELECTRIC LTD  
Delixi High-Tech Industrial Park  
Liushi Town, Yueqing City  
325604 Zhejiang Province, China

Subject: Type test

Requirements: EN 60947-2:2017, EN 60947-5-1:2017, IEC 60947-2:2016, IEC 60947-5-1:2016

Remark: This attestation is based on no. 3314517.01A issued on 2019-03-18.

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in test reports no. 3314907.50 issued on 2019-03-20 and 3314907.52 issued on 2019-03-20.

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Wenzhou, Zhejiang, 22 March 2019

Number: 3315374.01A

DEKRA Testing Services (Zhejiang) Co., Ltd.

Ms J Guo  
Certification Manager



© Integral publication of this attestation and adjoining reports is allowed  
The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.



DEKRA Testing Services (Zhejiang) Co., Ltd.

No. 5, Changjiang Road Great Bridge Industrial Park North Baixiang, Wenzhou, Zhejiang, 325603, P. R. China  
T +86577628680 00 F +86577629198 89 www.dekra-certification.com

**Ratings**

Number of poles	: 3P and 4P (protected N pole)
Protected poles	: 3 or 4
Rated operational voltage (Ue)	: 400 / 415 Vac, 660 / 690 Vac
Rated insulation voltage (Ui)	: 1000 V for main circuit 690 V for control circuit 690 V for auxiliary circuit
Rated impulse withstand voltage (Uimp)	: 12 kV for main circuit 4 kV for control circuit 4 kV for auxiliary circuit
Rated frequency	: 50 / 60 Hz
Rated current (In)	: 630 A, 800 A, 1000 A, 1250 A, 1600 A, 2000 A
Conventional thermal current (Ith)	: Equal to In
Current rating for four-pole circuit-breakers	: Equal to In
Suitable for isolation	: Suitable
Selectivity category	: B
Safety distance (screen-circuit breaker)	: Front / back: 0 mm Left / right: 0 mm Up / down: 0 mm
Reference temperature	: Independent
Method of mounting	: Withdrawable or fixed
EMC Environment	: A
Tightening torque for terminals	: 95 Nm for M12
Line/load terminal Connection	: Immaterial Minimum cross-sectional area of conductor: 185 x 2 mm <sup>2</sup> (copper conductor with cable lug) Maximum cross-sectional area of conductor: (100 mm x 5 mm) x 3 (copper busbars)
Inverse time delay release	: Ir (inverse time delay tripping setting): For trip unit: iTR326H and iTR326: Ir: (0,4 / 0,5 / 0,6 / 0,7 / 0,8 / 0,9 / 0,95 / 0,98 / 1) x In For trip unit: iTR326A: Ir: (0,4 - 1) x In, in steps of 1 A
Time setting of the inverse time delay release	: tr (inverse time delay tripping setting): 1 s / 2 s / 4 s / 8 s / 12 s / 16 s / 20 s / 24 s / 30 s, with tolerance of ± 10% (at 6 Ir) tripping time at 2 Ir: 8,1 s ≤ t ≤ 9,9 s (tr = 1 s) 243 s ≤ t ≤ 297 s (tr = 30 s)
Short time delay release	: I <sub>sd</sub> (short time delay tripping setting): For trip unit: iTR326H and iTR326: I <sub>sd</sub> : (1,5 / 2,0 / 3,0 / 4,0 / 5,0 / 6,0 / 8,0 / 10) x Ir, OFF For trip unit: iTR326A: I <sub>sd</sub> : (1,5 - 10) x Ir, OFF in steps of 1 A for I <sub>sd</sub> < 10 kA, in steps of 0,01 kA for I <sub>sd</sub> ≥ 10 kA

Time setting of the short time delay release	tsd (short time delay tripping setting): $I^2t$ off: 0,1 s / 0,2 s / 0,3 s / 0,4 s 0,1 s, with tolerance of 80 ms - 140 ms 0,2 s, with tolerance of 140 ms - 200 ms 0,3 s, with tolerance of 230 ms - 320 ms 0,4 s, with tolerance of 350 ms - 500 ms Non-tripping duration: 0,1 s: 80 ms 0,2 s: 140 ms 0,3 s: 230 ms 0,4 s: 350 ms
Instantaneous release	: li (instantaneous tripping setting): For trip unit: iTR326H and iTR326: li: (2 / 3 / 4 / 6 / 8 / 10 / 12 / 15) x $I_n$ , OFF For trip unit: iTR326A: li: (2 - 15) x $I_n$ , OFF in steps of 1 A for li < 10 kA, in steps of 0,01 kA for li ≥ 10 kA
Making current release (MCR)	: 24 kA
Ground fault release	: Ig (ground fault release tripping setting): For trip unit: iTR326H and iTR326: In < 1250 A: Ig: (0,2 / 0,3 / 0,4 / 0,5 / 0,6 / 0,8 / 0,9 / 1,0) x $I_n$ , OFF In ≥ 1250 A: Ig: 500 A / 600 A / 700 A / 800 A / 900 A / 1000 A / 1100 A / 1200 A, OFF For trip unit: iTR326A: In < 1250 A: Ig: (0,2 - 1,0) x $I_n$ , in steps of 1 A, OFF In ≥ 1250 A: Ig: 500 A - 1200 A, in steps of 1 A, OFF tg (ground fault release tripping setting): $I^2t$ off: 0,1 s / 0,2 s / 0,3 s / 0,4 s 0,1 s, with tolerance of 80 ms - 140 ms 0,2 s, with tolerance of 140 ms - 200 ms 0,3 s, with tolerance of 230 ms - 320 ms 0,4 s, with tolerance of 350 ms - 500 ms
Shunt release	: AC: 220 / 230 V, 380 / 400 V, 50 / 60 Hz DC: 110 V, 220 V
Under-voltage release	: AC: 220 / 230 V, 380 / 400 V, 50 / 60 Hz
Closing coil	: AC: 220 / 230 V, 380 / 400 V, 50 / 60 Hz DC: 110 V, 220 V
Stored energy motor	: AC: 220 / 230 V, 380 / 400 V, 50 / 60 Hz DC: 110 V, 220 V
External supply for trip unit	: AC: 220 / 230 V, 380 / 400 V, 50 / 60 Hz DC: 110 V, 220 V
auxiliary circuits	: 4 NO and 4 NC AC-15: 0,9 A at 400 Vac, 1,5 A at 230 Vac DC-13: 0,27 A at 220 Vdc, 0,55 A at 110 Vdc Ui: 690 Vac, Uimp: 4 kV Rated conditional short-circuit current: 1 kA Fuse: RL1-10, 10 A, 400 Vac, 25 kA

**Product rating - HDW3-2000M**

rated ultimate short-circuit breaking capacity (I <sub>cu</sub> )	:	80 kA at 400 / 415 Vac
		50 kA at 660 / 690 Vac
rated service short-circuit breaking capacity (I <sub>cs</sub> )	:	65 kA at 400 / 415 Vac
		40 kA at 660 / 690 Vac
rated short-time withstand current (I <sub>cw</sub> )	:	65 kA - 1 s at 400 / 415 Vac
		40 kA - 1 s at 660 / 690 Vac

**Product rating - HDW3-2000S**

rated ultimate short-circuit breaking capacity (I <sub>cu</sub> )	:	65 kA at 400 / 415 Vac
		40 kA at 660 / 690 Vac
rated service short-circuit breaking capacity (I <sub>cs</sub> )	:	65 kA at 400 / 415 Vac
		40 kA at 660 / 690 Vac
rated short-time withstand current (I <sub>cw</sub> )	:	65 kA - 1 s at 400 / 415 Vac
		40 kA - 1 s at 660 / 690 Vac

## Additional information

Nomenclature breakdown:

HDW3 - 2000 M / 4

a            b   c   d

a = Model name: HDW3

b = Frame size: 2000

c = short-circuit capacity: 'S' or 'M'

d = pole numbers, '4' means 4P ACBs, 'blank' means 3P ACBs