

## **CERTIFICATE**FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2001441

Circuit-breakers

Type designation:	HDM2-125***
Certificate holder:	HIMEL HONG KONG LIMITED 11/F Kerry Crt 683 King's Rd Quarry Bay Hong Kong
The product complies w the standard(s):	ith EN 60947-2:2017
Date of expiry:	04 May, 2025
EU Directive information	According to the principle of presumption of conformity, this certificate constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.
Additional information in	Appendix
Certification Body:	Intertek Semko AB, Product Certification Place: Kista - Stockholm
Signed:	Date: 04 May, 2020
	Leif Mattsson

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Intertek Semko AB Page 1 of 2



## **APPENDIX:**

Reference No. SE-S-2001441

Technical Data: Type designation Rated voltage (V) Rated current (A) Frequency (Hz) IP-Class Poles No. Trademark Test Report Product information	HDM2-125*** Ue= 220/240V for 1P, Ue= 220/240/400V for 2P 10, 16, 20, 25, 32, 40, 50, 63, 80, 100, 125A; 50/60 20 1P, 2P  /// // Lic=20kA/220/240V, Ics=15kA/220/240V for 1P. Icu=30kA/220/240V, Ics=18kA/220/240V, Icu=20kA/400V, Ics=15kA/400V for 2P Cat: A, Ii=10In, Uimp=8kV, Ui=690V  Explanation type designation: HD M 2 - 125 * * * (I) (II) (III) (IV) (V) (VI) (VII) I Himel II MCCB III Design number IV Frame size V Breaking class: L VI Rated current: 10, 16, 20, 25, 32, 40, 50, 63, 80, 100, 125A VII Number of pole; 1, 2
Manufacturing Sites:	DELIXI ELECTRIC LTD Delixi High Tech Industrial Park, Liushi Town, Yueqing City, Zhejiang Province China 325604
	DELIXI ELECTRIC (WUHU) LTD Wuhu Machinery Industrial Park, Wuhu City, Anhui Province, China 241100
constitutes support for Directive 2014/35/EU. This presumption can e	ole of presumption of conformity, this certificate, which includes production control, an EC Declaration of Conformity and CE marking according to the Low Voltage xpire before end of validity of this certificate due to new issued Standard or es within the EU legislation.
Certification Body:	Intertek Semko AB, Product Certification Place: Kista - Stockholm
Signed:	Date: 04 May, 2020

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Leif Mattsson

Intertek Semko AB Page 2 of 2