

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50548018

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*
G.J.Q.

Unser Zeichen *Our Reference*
01-SDW-CN22MAKI 002

Ausstellungsdatum *Date of Issue*
29.06.2022
(day/mo/yr)

Genehmigungsinhaber *License Holder*
HIMEL HONG KONG LIMITED
11/F KERRY CTR
683 KING'S RD QUARRY BAY
Hong Kong

Fertigungsstätte *Manufacturing Plant*
040-0002007190

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
EN 60831-1:2014
IEC 60831-1:2014

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Capacitor (Shunt Power Capacitor)

Type Designation : HBSM-0-250V-xkvar-1phase-y 9
(x,y are variable, x=0.5;1;2;
2.5;3;4;5;6;7.5;8;10;12;14;15;
16;18;20;25;28;30;35;40 stands
for rated output under 50Hz,
y= D;M;Q stands for case type)

Rated Voltage : AC 250V

Rated Frequency : 50Hz/60Hz

Rated Output of Capacitor : 0,5;1;2;2,5;3;4;5;6;7.5;8;10;12;
14;15;16;18;20;25;28;30;35;40
(50Hz)
0,6;1,2;2,4;3,0;3,6;4,8;6,0;7,2;
9,0;9,6;12;14,4;16,8;18;19,2;
21,6;24;28,8;30;33,6;36;42;48
(60Hz)

Continued on page 0002

9

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

<http://www.tuv.com/safety> E-mail: markcheck@tuv.com
Fax: +49 221 806-3935



Kenny Shi

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50548018

Blatt *Sheet*
0002

Ihr Zeichen *Client Reference*
G.J.Q.

Unser Zeichen *Our Reference*
01-SDW-CN22MAKI 002

Ausstellungsdatum *Date of Issue*
29.06.2022
(day/mo/yr)

Genehmigungsinhaber *License Holder*
HIMEL HONG KONG LIMITED
11/F KERRY CTR
683 KING'S RD QUARRY BAY
Hong Kong

Fertigungsstätte *Manufacturing Plant*
040-0002007190

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
EN 60831-1:2014
IEC 60831-1:2014

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Capacitor (Shunt Power Capacitor)

Continuation from page 0001

Connection Type : single phase
Temperature Category : -25/C
Self-healing Capacitor : Yes
Discharge Device : Yes
Service Condition : Indoor Use, ≤2000m

Remark:

Self-healing test in accordance with IEC 60831-2:2014 is also conducted and passed.

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
<http://www.tuv.com/safety> E-mail: markcheck@tuv.com
Fax: +49 221 806-3935



Kenny Shi

HIMEL HONG KONG LIMITED
Jianquan Guo

11/F KERRY CTR
683 KING'S RD QUARRY BAY
Hong Kong

Date : 29.06.2022
Our ref. : SDW 01
Your ref.: G.J.Q.

Ref : R TÜV-Mark Approval

Type of Equipment : Shunt Power Capacitor
Model Designation : See Certificate
Certificate No. : R 50548018 0001
Report No. : CN22MAKI 002

Dear Jianquan Guo,

The above specified technical equipment has been tested and found to be in accordance with the relevant requirements.

Enclosed you will find the certificate of approval.


If cancellation of the certificate is submitted by November 15 in a given year, no fee will be charged for the following year.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

Please contact our office for approval of your new products.

With kind regards,

Certification Body


Kenny Shi

cc: DELIXI ELECTRIC LTD

Enclosure

证书的详细资料请登陆www.tuvdotcom.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询