

IEC**IECEE
CB
SCHEME**

Ref. Certif. No.

HU-001759-A1

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME****CB TEST CERTIFICATE****Product**

Residual current operated circuit-breakers without integral over-current protection (RCCBs)

Name and address of the applicantDELIXI ELECTRIC LTD
Delixi High Tech Industrial Park, Liushi Town,
Yueqing City, Zhejiang Province,
China 325604**Name and address of the manufacturer**DELIXI ELECTRIC LTD
Delixi High Tech Industrial Park, Liushi Town,
Yueqing City, Zhejiang Province,
China 325604**Name and address of the factory***Note: When more than one factory, please report on page 2*DELIXI ELECTRIC LTD
Delixi High Tech Industrial Park, Liushi Town,
Yueqing City, Zhejiang Province,
China 325604**Ratings and principal characteristics**Un=230-240V~ (2P); 400-415V~(4P); 50/60Hz;
In = 10A, 16A, 20A, 25A, 32A, 40A, 63A;
IAn = 10mA (only for 2P, In=10, 16, 20, 25A); 30, 100,
300 and 500mA;
Type A or Type AC, without time-delay;
Im = IAm = 500A or 10In (whichever is the greater);
IAc = Inc = 6,0kA**Trademark (if any)****Customer's Testing Facility (CTF) Stage used**

Model / Type Ref.

HDB3VR

Additional information (if necessary may also be reported on page 2)

This Certificate is amendment No.1 to CB Test Certificate ref. No. HU-001759, dated 2016-03-31 and it is issued due to change of Applicant.

A sample of the product was tested and found to be in conformity withIEC 61008-1:2010 + AMD1:2012 + AMD2:2013
IEC 61008-2-1:1990
EU Group Differences**As shown in the Test Report Ref. No. which forms part of this Certificate**

1W150102-B1-M1

This CB Test Certificate is issued by the National Certification Body

**TÜVRheinland®**TÜV Rheinland InterCert Kft., Division MEEI
H-1132 Budapest, Váci út 48/A-B
www.tuv.com

Date: 2019-09-03

Signature:

Tünde Potencsik